

ITEM 14c. Main Line Valve Spacing and Inspections

Spacing 30% maximum deficiency

Standard is 500 feet in commercial areas, 800 feet in residential areas

Inspections 70% maximum deficiency

<u>FREQUENCY</u>	<u>DEFICIENCY</u>
10-inch and larger twice per year and other yearly	0%
All yearly	10%
2 years	25%
3 years	40%
4 years	55%
5 years or more	70%